

Town of Scituate
Request for Proposals
Skid Mounted Fire Pump

The Town of Scituate posts a Request for Pricing for one Diesel Powered Fire Pump with installation and removal of existing pump. Any questions on specifications given or substitutions for potential quotes, please email Chief Keith Brown, Chopmist Hill VFD at chvfdchief@gmail.com.

Sealed bids will be received at the Town Clerk's Office, 195 Danielson Pike, North Scituate, Rhode Island until 3:00 p.m. prevailing time on August 10, 2018, 2018 at which time all bids will be opened publicly.

The successful bidder must have an apparatus repair facility located within 35 miles of the Scituate Town Hall, 195 Danielson Pike, North Scituate, RI 02857.

The Town reserves the right to reject any and all bids, or parts thereof, and waive any irregularity in the bids received, and to accept the bid, or parts thereof, deemed to be the most favorable to the best interest of the Town.

BID EQUIPMENT SPECIFICATIONS

One Skid Mounted Fire Pump:

- One (1) CET Fire Pumps MFG Model SM-PFP-25hp-DSL-MR (No Exceptions)
- Scotty Foam System
- 3 outlet manifold with 1 ½", 2 ½" and 1" Booster Reel with valved outlets. The valve terminations shall be male.
- One (1) 2 ½" Suction Inlet with a "Fire Type" valve. The swivel shall be female.
- One (1) 2 ½" tank to pump valve.

ADDITIONAL WORK TO BE PERFORMED

- Remove existing pump and the pump's gasoline fuel tank from apparatus.
- Mount new pump to the existing skid on the vehicle.
- Connect new pump to apparatus fuel tank (diesel).
- Remount Booster Reel at location as agreed by Fire Chief.
- Connect new pump to existing tank/booster reel and new piping.

The unit will be installed on a 1999 Ford F-550 Pickup chassis (diesel). Pricing must include parts necessary to provide the fuel supply for the new pump to be provided from the F-550 main fuel tank, and whatever labor would be involved to complete the installation.